

# City of Wrens 2015 Drinking Water Consumer Confidence Report

---

## **Is my water safe?**

Last year, as in years past, your tap water met all U.S. Environmental Protection Agency (EPA) and state drinking water health standards. The City of Wrens vigilantly safeguards its water supplies and once again we are proud to report that our system has not violated a maximum contaminant level or any other water quality standard.

## **Do I need to take special precautions?**

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/Centers for Disease Control (CDC) guidelines on appropriate means to lessen the risk of infection by Cryptosporidium and other microbial contaminants are available from the Safe Water Drinking Hotline (800-426-4791).

## **Where does my water come from?**

Wrens gets its water from the Cretaceous aquifer.

## **Source water assessment and its availability**

In order to ensure that tap water is safe to drink, EPA prescribes regulations which limit the amount of certain contaminants in water provided by public water systems.

We constantly monitor for various contaminants in the water supply to meet all regulatory requirements. We have detected no contaminants in our water system. This monitoring provides us with clean and safe water.

Thank you for allowing us to provide your family with clean, quality water this year.

## **Why are there contaminants in my drinking water?**

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency's (EPA) Safe Drinking Water Hotline (800-426-4791). The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity. Microbial contaminants, such as viruses and bacteria that may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife. Inorganic contaminants, such as salts and metals, which can be naturally occurring or result from urban stormwater runoff, industrial, or domestic wastewater discharges, oil and gas production, mining, or farming. Pesticides and herbicides, which may come from a variety of sources such as agriculture, urban stormwater runoff, and residential uses. Organic Chemical Contaminants, including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, and can also, come from gas stations, urban stormwater runoff, and septic systems. Radioactive contaminants, which can be naturally occurring or be the result of oil and gas production and mining activities. In order to ensure that tap water is safe to drink, EPA prescribes regulations that limit the amount of certain contaminants in water provided by public water systems. Food and Drug Administration (FDA) regulations establish limits for contaminants in bottled water which must provide the same protection for public health.

## **How can I get involved?**

Please call our office if you have questions. The City of Wrens employees work around the clock to provide top quality water to every tap. We ask that you, the customer, help us protect our water source which is the heart of our community, which will ensure our way of life and our children's future.

## Water Quality Data Table

The table below lists all of the drinking water contaminants that we detected during the calendar year of this report. The presence of contaminants in the water does not necessarily indicate that the water poses a health risk. Unless otherwise noted, the data presented in this table is from testing done in the calendar year of the report. The EPA or the State requires us to monitor for certain contaminants less than once per year because the concentrations of these contaminants do not change frequently.

<u>Contaminants</u>	<u>MCLG</u> or <u>MRDLG</u>	<u>MCL,</u> <u>TT, or</u> <u>MRDL</u>	<u>Your</u> <u>Water</u>	<u>Range</u> <u>Low</u> <u>High</u>		<u>Sample</u> <u>Date</u>	<u>Violation</u>	<u>Typical Source</u>
<b>Disinfectants &amp; Disinfection By-Products</b>								
(There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.)								
TTHMs [Total Trihalomethanes] (ppb)	NA	80	0	0	0	2013	No	By-product of drinking water disinfection
<b>Inorganic Contaminants</b>								
Fluoride (ppm)	4	4	0.88	0.74	1.26	2015	No	Erosion of natural deposits; Water additive which promotes strong teeth; Discharge from fertilizer and aluminum factories
Nitrate [measured as Nitrogen] (ppm)	10	10	0.63	ND	1.90	2015	No	Runoff from fertilizer use; Leaching from septic tanks, sewage; Erosion of natural deposits
<b>Microbiological Contaminants</b>								
Fecal coliform/E. coli (positive samples)	0	0	0	NA		2015	No	Human and animal fecal waste
A violation occurs when a routine sample and a repeat sample, in any given month, are total coliform positive, and one is also fecal coliform or E. coli positive.								
Total Coliform (positive samples/month)	0	0	0	0	0	2015	No	Naturally present in the environment
<b>Inorganic Contaminants</b>								
<u>Contaminants</u>	<u>MCLG</u>	<u>AL</u>	<u>Your</u> <u>Water</u>	<u>Sample</u> <u>Date</u>	<u># Samples</u> <u>Exceeding AL</u>	<u>Exceeds</u> <u>AL</u>	<u>Typical Source</u>	
Copper - action level at consumer taps (ppm)	1.3	1.3	0.36	2013	0	No	Corrosion of household plumbing systems; Erosion of natural deposits	
Lead - action level at consumer taps (ppb)	0	15	0	2013	0	No	Corrosion of household plumbing systems; Erosion of natural deposits	

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. The City of Wrens is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/safewater/lead>

# Undetected Contaminants

The following contaminants were monitored for, but not detected, in your water.

<u>Contaminants</u>	<u>MCLG</u> or <u>MRDLG</u>	<u>MCL</u> or <u>MRDL</u>	<u>Your</u> <u>Water</u>	<u>Violation</u>	<u>Typical Source</u>
---------------------	-----------------------------------	---------------------------------	-----------------------------	------------------	-----------------------

<b>Unit Descriptions</b>	
<u>Term</u>	<u>Definition</u>
Ppm	ppm: parts per million, or milligrams per liter (mg/L)
Ppb	ppb: parts per billion, or micrograms per liter (µg/L)
positive samples/month	positive samples/month: Number of samples taken monthly that were found to be positive
positive samples	positive samples/yr: The number of positive samples taken that year
NA	NA: not applicable
ND	ND: Not detected
NR	NR: Monitoring not required, but recommended.

<b>Important Drinking Water Definitions</b>	
<u>Term</u>	<u>Definition</u>
MCLG	MCLG: Maximum Contaminant Level Goal: The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.
MCL	MCL: Maximum Contaminant Level: The highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.
TT	TT: Treatment Technique: A required process intended to reduce the level of a contaminant in drinking water.
AL	AL: Action Level: The concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.
Variances and Exemptions	Variances and Exemptions: State or EPA permission not to meet an MCL or a treatment technique under certain conditions.
MRDLG	MRDLG: Maximum residual disinfection level goal. The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.
MRDL	MRDL: Maximum residual disinfectant level. The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.
MNR	MNR: Monitored Not Regulated
MPL	MPL: State Assigned Maximum Permissible Level

## For more information please contact:

Larry Anderson  
 Water Superintendent  
 415 West Walker St  
 Wrens, GA 30833  
 706-547-3000 phone  
 706-547-3002 fax